

January 16, 2023

**Meadowlark Ranches Mutual Water Co.**

Attn: Mike Hadley

P.O. Box 606

Santa Ynez, CA 93460-0606

SP 2300060:1 **Coliform Bacteria Analysis**

Customer ID : 2021676

System Number : 4200612

Project Name : Routine Bacteriological

**Analytical Results**

ID	Sample Description	Total	Fecal	E. Coli	Units	Method	Prep	Footnote
1	SS at White Oak	Absent	---	Absent	A/P/100ml	SM 9223B	Colilert-P/A 18	

N/R Not Required

MPN Most Probable Number

A/P Absence/Presence

**The samples listed above were Acceptable for both Total and Fecal Coliform**

**Sample Handling Information**

ID	Sample Number	System Number	Sample Type/Reason	Sampler	Employed By	Sampled
1	SP 2300060-001	4200612	System-Routine	Matthew Jimenez	FGL Environmental	2023-01-03 10:00

**Field Analysis/QA Information**

ID	Sample Description	Cl Total/Free mg/l	Temp	Analysis Started	Analysis Completed	Contact	Contacted
1	SS at White Oak	---/0.87	---	2023-01-03 17:05 mdr	2023-01-04 12:45 ccm	N/R	

Analyses were performed at the FGL Santa Paula Laboratory using Standard Methods 20th edition. If you have any questions regarding your results, please call. The FGL Santa Paula Laboratory is certified by California ELAP #1573 and accredited to ISO/IEC 17025:2017 by PJLA certificate #75605, Testing.

Prepared By: SMH

cc:SBCEH

Reviewed and  
Approved By

**Raquel R. Harvey**



Digitally signed by Raquel R. Harvey  
Title: Tech Director Microbiology  
Date: 2023-01-16

