

February 18, 2017

**Meadowlark Ranches Mutual Water Co.**

Attn: Mike Hadley  
 P.O. Box 606  
 Santa Ynez, CA 93460-0606

SP 1702033:1 **Coliform Bacteria Analysis**

Customer ID : 2021676

System Number : 4200612

Project Name : Routine Bacteriological

**Analytical Results**

ID	Sample Description	Total	Fecal	E. Coli	Units	Method	Prep	Footnote
1	SS at White Oak	Absent	---	Absent	A/P/100ml	SM 9223B	Colilert-P/A	

N/R Not Required

MPN Most Probable Number

A/P Absence/Presence

**The samples listed above were Acceptable for both Total and Fecal Coliform**

**Sample Handling Information**

ID	Sample Number	System Number	Sample Type/Reason	Sampler	Employed By	Sampled
1	SP 1702033-001	4200612	System-Routine	Matthew Jimenez	FGL Environmental	2017-02-15 09:48

**Field Analysis/QA Information**

ID	Sample Description	Cl Total/Free mg/l	Temp	Analysis Started	Analysis Completed	Contact	Contacted
1	SS at White Oak	---/0.59	---	2017-02-15 15:09 rv	2017-02-16 16:45 rv	N/R	

Analyses were performed at the FGL Santa Paula Laboratory using Standard Methods 20th edition. If you have any questions regarding your results, please call. The FGL Santa Paula Laboratory is certified by California ELAP #1573 and ISO/IEC 17025:2005 PJLA, #75605, Testing.

Prepared By: SMH

cc:SBCEH

Reviewed and  
Approved By

**Raquel R. Harvey**



Digitally signed by Raquel R. Harvey  
 Title: Tech Director Microbiology  
 Date: 2017-02-19



**CHAIN OF CUSTODY**  
*www.fglinc.com*

Client:				1677-02/20/2017		TEST DESCRIPTION - See Reverse side for Container, Preservative and Sampling information												L215			
Meadowlark Ranches Mutual Water Co. Address: Attn: Mike Hadley P.O. Box 606 Santa Ynez, CA 93460-0606				Method of Sampling: Composite(C) Grab(G)	Type of Sample **SEE REVERSE SIDE**	Potable(P) Non-Potable(NP) Ag Water(AgW)	Bacti Type: Other(O) System(SYS) Source(SR) Waste(W)	Bacti Reason: Routine(ROUT) Repeat(RPT) Replace(RPL) Other(O) Special(SPL)	Coliform - Colilert-P/A 120ml(PBa)-Na2S2O3	Field Test-Field CI Free	Sampling Fee										
Phone: (805)688-3132 Fax:																					
Contact Person: Mike Hadley																					
Project Name: Routine Bacteriological																					
Purchase Order Number:																					
Quote Number:																					
Sampler(s) <i>M. Jimenez</i>																					
Sampling Fee: _____ Pickup Fee: _____																					
Compositor Setup Date: ____/____/____ Time: ____/____																					
Lab Number: SP <i>1702033</i> 2-21676																					
Samp Num	Location Description	Date Sampled	Time Sampled																		
1	SS at White Oak	<i>2/15/17</i>	<i>9:48</i>	G	DW				1	<i>0.59</i>	X										
Remarks:				Relinquished				Date:	Time:	Relinquished				Date:	Time:	Relinquished				Date:	Time:
<i>5C</i>				<i>[Signature]</i>				<i>2/15/17</i>	<i>1430</i>												
				Received By:				Date:	Time:	Received By:				Date:	Time:	Received By:				Date:	Time:
				<i>[Signature]</i>																	

**9415 W. Goshen Avenue  
Visalia, CA 93291  
Phone: (559) 734-9473  
Fax: (559) 734-8435**