

April 11, 2022

Meadowlark Ranches Mutual Water Co.

Attn: Mike Hadley

P.O. Box 606

Santa Ynez, CA 93460-0606

SP 2205319:1 **Coliform Bacteria Analysis**

Customer ID : 2021676

System Number : 4200612

Project Name : Routine Bacteriological

Analytical Results

ID	Sample Description	Total	Fecal	E. Coli	Units	Method	Prep	Footnote
1	SS at White Oak	Absent	---	Absent	A/P/100ml	SM 9223B	Colilert-P/A 18	

N/R Not Required

MPN Most Probable Number

A/P Absence/Presence

The samples listed above were Acceptable for both Total and Fecal Coliform

Sample Handling Information

ID	Sample Number	System Number	Sample Type/Reason	Sampler	Employed By	Sampled
1	SP 2205319-001	4200612	System-Routine	Matthew Jimenez	FGL Environmental	2022-04-04 10:20

Field Analysis/QA Information

ID	Sample Description	Cl Total/Free mg/l	Temp	Analysis Started	Analysis Completed	Contact	Contacted
1	SS at White Oak	---/0.96	---	2022-04-04 16:37 lkb	2022-04-05 12:05 lm	N/R	

Analyses were performed at the FGL Santa Paula Laboratory using Standard Methods 20th edition. If you have any questions regarding your results, please call. The FGL Santa Paula Laboratory is certified by California ELAP #1573 and accredited to ISO/IEC 17025:2017 by PJLA certificate #75605, Testing.

Prepared By: RRH

cc:SBCEH

Reviewed and
Approved By

Raquel R. Harvey



Digitally signed by Raquel R. Harvey
Title: Tech Director Microbiology
Date: 2022-04-11



Office & Laboratory
9415 W. Goshen Avenue
Visalia, CA 93291
Phone: (559) 734-9473
Fax: (559) 734-8435